

## **Purpose of Study**

The purpose of this evaluation is to assess potential constraints on the transmission systems of the SERTP Sponsors, as defined on the SERTP website, for the stakeholder requested economic planning studies selected by the Regional Planning Stakeholder Group (“RPSG”). This assessment will include the identification of transmission enhancements within the Sponsors’ footprint necessary to accommodate the economic planning study requests. Transmission planners of the Sponsors will perform the studies. The study results will be reviewed with the SERTP stakeholders for their input prior to the finalization of the study.

## **Overview of the Study Process**

The scope of the proposed study process will include the following steps:

### **1. Assumptions**

- Study assumptions selected

### **2. Study Criteria**

- Outline the criteria by which the evaluation results will be measured

### **3. Case Development**

- Develop the models needed to perform the evaluations

### **4. Methodology**

- Outline the methodologies that will be used to carry out the evaluation

### **5. Technical Analysis and Study Results**

- Perform the analyses (thermal, voltage, stability, and short circuit, as necessary for the study) and produce the results

### **6. Assessment and Problem Identification**

- Evaluate the results to identify constraints / issues

### **7. Solution Development**

- Identify potential solutions to the constraints / issues
- Test the effectiveness of the potential solutions through additional evaluations (thermal, voltage, stability, and short circuit as necessary) and modify the solutions as necessary such that each Sponsor’s planning criteria are met
- Provide cost estimates of the necessary transmission enhancements
- Provide associated timelines for completion for each of the proposed solutions

## **8. Report on the Study Results**

- Prepare a report on the identified system upgrades to accommodate the economic planning study requests

Each of these study steps is described in more specific detail below.

## **Assumptions**

The specific assumptions selected for these evaluations are:

- Each request will only be evaluated for the particular year and load level identified below, as selected by the RPSG
- The following scenarios will be evaluated:

### **1) SPP to TVA – 800 MW**

- Year: 2030
- Load Level: Winter Peak
- Type of Transfer: Generation to Load
- Source: Generation within SPP (+800 MW)
- Sink: Load within TVA (+800 MW)

### **2) FRCC to SOCO – 1500 MW**

- Year: 2030
- Load Level: Shoulder
- Type of Transfer: Generation to Load
- Source: Generation within FRCC (+1500 MW)
- Sink: Load within SOCO (+1500 MW)

### **3) MISO South to DEP/DEC – 1000 MW**

- Year: 2030
- Load Level: Winter Peak
- Type of Transfer: Generation to Generation
- Source: Generation within MISO South (+1000 MW)
- Sink: Generation within DEC (-600 MW) and DEP (-400 MW)

### **4) MISO South to DEP/DEC – 2000 MW**

- Year: 2030
- Load Level: Winter Peak
- Type of Transfer: Generation to Generation
- Source: Generation within MISO South (+2000 MW)
- Sink: Generation within DEC (-1200 MW) & DEP (-800 MW)

**5) MISO South to DEP/DEC – 2000 MW**

- Year: 2030
- Load Level: Summer Peak
- Type of Transfer: Generation to Generation
- Source: Generation within MISO South (+2000 MW)
- Sink: Generation within DEC (-1200 MW) & DEP (-800 MW)

DRAFT

## **Study Criteria**

The study criteria with which results will be evaluated will include each individual Sponsors' planning criteria (voltage, thermal, stability, and short circuit), which is posted on the SERTP website.

## **Case Development**

- For all evaluations, the latest series SERTP regional models available will be used as a starting point for the analysis of the economic planning study requests.

## **Methodology**

- Initially, power flow analyses will be performed based on the assumption that thermal limits will be the most limiting constraint. Voltage, stability, and short circuit studies may be performed if circumstances warrant.
- PSS/E, TARA, and/or MUST will be used for the study.

## **Technical Analysis and Study Results**

The technical analysis will be performed in accordance with the study methodology. Results from the technical analysis will be reported throughout the study area to identify transmission elements approaching their limits such that all Sponsors and stakeholders are aware of potential issues and appropriate steps can be identified to address these issues.

The report will include, at a minimum, results for monitored transmission elements within the Sponsors' footprint based on:

- Thermal loadings greater than 90% for facilities that are negatively impacted by the proposed transfers and change by +5% of applicable rating with the addition of the transfer(s)
- Voltage limitations appropriate to each Sponsor's planning criteria

## **Assessment and Problem Identification**

- Each Sponsor will run assessments in order to identify any constraints within the Sponsors' footprint as a result of the economic planning study requests. Each Sponsor will apply its respective planning criteria for its facilities and any reliability constraints identified will be documented and reviewed by each Sponsor.

## **Solution Development**

- The Sponsors, with input from the stakeholders, will develop potential transmission solution alternatives due to the economic studies requested by the RPSG.
- The Sponsors will test the effectiveness of the potential transmission solution alternatives using the same cases, methodologies, assumptions and criteria described above.
- The Sponsors will develop high-level, planning-grade cost estimates and in-service dates for the selected solution alternatives.

## **Report on the Study Results**

The Sponsors will compile all the study results and prepare a report for review by the stakeholders. The report shall contain the following:

- A description of the study approach and key assumptions for the economic planning studies
- For each economic planning study, the results of that study include:
  1. Limits to the transfer
  2. Selected transmission solution alternatives to address the limit
  3. High-level, planning-grade cost estimates and in-service dates for the selected transmission solution alternatives